

Day	pH	Alk	Phos	Other	Y/N
1	off				
2	7.4	138			Y
3	7.5				Y
4	7.5				Y
5	7.6				Y
6	7.6				Y
7	7.8				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.5				Y
12	7.6				Y
13	7.5				Y
14	7.7				Y
15	7.5	120			Y
16	7.6				Y
17	7.8				Y
18	7.5				Y
19	7.6				Y
20	7.6				Y
21	Off				Y
22	Off				Y
23	7.5	127			Y
24	Off				Y
25	7.6				Y
26	7.6				Y
27	Off				Y
28	7.5				Y
29	7.6				Y
30	7.6				Y
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	7	9	2
---	---	---	---	---

System Name: City of Scappoose

Entry Point: B

Sample Period: September 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>90.0</u>	(Alkalinity)
PO4	<u></u>	(Orthophosphate)
Other	<u></u>	(_____)

Print Name: Kevin Turner

Signature: Kevin Turner

Date: 10/08/2025

Send to DWP within 10 days after end of sampling period