

Day	pH	Alk	Phos	Other	Y/N
1	7.5	129			Y
2	7.5				Y
3	7.4				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.6				Y
8	7.4				Y
9	7.6	128			Y
10	7.8				Y
11	7.8				Y
12	7.6				Y
13	7.6				Y
14	7.7				Y
15	7.7				Y
16	7.6	124			Y
17	Off				
18	7.6				Y
19	7.7				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.7	131			Y
25	7.6				Y
26	7.7				Y
27	7.7				Y
28	7.6				Y
29	7.6	128			Y
30	7.6				Y
31	7.6				Y

(No = N = Excursion) **Total N's**

0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41- 00792

System Name: City of Scappoose

Entry Point: B

Sample Period: October 2025

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk 90.0 *(Alkalinity)*

Print Name: Kevin Turner

Signature: *Kevin Turner*

Date: November 6, 2025

Send to DWP within 10 days after end of
sampling period