

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6	129			Y
3	7.7				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6	132			Y
9	7.6				Y
10	7.6				Y
11	7.5				Y
12	7.6				Y
13	7.7				Y
14	7.6				Y
15	7.6	134			Y
16	7.6				Y
17	7.7				
18	7.6				Y
19	7.7				Y
20	7.6				Y
21	7.7				Y
22	7.6	126			Y
23	7.6				Y
24	7.7				Y
25	7.7				Y
26	7.6				Y
27	7.7				Y
28	7.7				Y
29	7.8	126			Y
30	7.6				Y
31	7.6				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41- 00792

System Name: City of Scappoose

Entry Point: B

Sample Period: January 2026

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2
Alk	90.0

(Alkalinity)

Print Name: Kevin Turner

Signature:

Date:

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0