

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7	128			Y
3	7.6				Y
4	7.5				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6	130			Y
10	7.6				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.7	126			Y
19	7.6				Y
20	7.5				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.5	124			Y
25	7.5				Y
26	7.5				Y
27	7.5				Y
28	7.5				Y

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41- 00792**

**System Name: City of Scappoose**

**Entry Point: B**

**Sample Period: February 2026**

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

  
Alk 

90.0
------

 (Alkalinity)

**Print Name: Kevin Turner**

**Signature: *Kevin Turner***

**Date: March 6, 2026**

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**