

Day	pH	Alk	Phos	Other	Y/N
1					
2	8.7				y
3	8.3				y
4	8.1				y
5	7.9				y
6	8.1				y
7	8.1				y
8	8.1				y
9	8.0				y
10	7.9				y
11	8.1				y
12	8.0				y
13	7.8				y
14	7.8				y
15	7.6				y
16	7.7				y
17	7.7				y
18	7.8				y
19	7.8				y
20	7.8				y
21	7.8				y
22	OFF				
23	7.8				y
24	7.4				y
25	7.4				y
26	7.4				y
27	7.5				y
28	7.4				y
29	7.4				y
30	7.3				y
31	7.9				y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100792**

**SCAPPOOSE, CITY OF**

Sample period: May 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
Alk            (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 6/4/2021 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0