

Day	pH	Alk	Phos	Other	Y/N
1	8.5				Y
2	8.4				Y
3	8.8				Y
4	9.1				Y
5	8.8				Y
6	8.7				Y
7	8.6				Y
8	8.6				Y
9	8.06				Y
10	8.0				Y
11	7.9				Y
12	7.8				Y
13	8.7				Y
14	8.31				Y
15	8.7				Y
16	8.5				Y
17	8.5				Y
18	8.5				Y
19	7.9				Y
20	8.1				Y
21	8.1				Y
22	8.0				Y
23	8.0				Y
24	7.6				Y
25	7.2				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.5				Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100792**  
**SCAPPOOSE, CITY OF**

Sample period: SEPT. 2022  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH   
Alk  (Alkalinity)

Print Name: Darryl Sykes  
Signature: Darryl Sykes  
Date & Phone#: 10/6/2022 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's