

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.2				Y
3	7.3				Y
4	7.3				Y
5	7.2				Y
6	7.5				Y
7	7.6				Y
8	7.5				Y
9	7.6				Y
10	7.6				Y
11	7.5				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.7				Y
16	7.5				Y
17	7.4				Y
18	7.2				Y
19	7.3				Y
20	7.3				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.3				Y
26	7.3				Y
27	7.3				Y
28	7.2				Y
29	7.9				Y
30	7.8				Y
31	7.7				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample period: Oct 2027
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 11/10/2022 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0