

Day	pH	Alk	Phos	Other	Y/N
1	OFF				
2	OFF				
3	7.6				Y
4	7.7				Y
5	OFF				
6	7.5				Y
7	OFF				
8	7.5				Y
9	OFF				
10	OFF				
11	7.6				Y
12	7.5				Y
13	7.5				Y
14	OFF				
15	7.5				Y
16	OFF				
17	7.5				Y
18	7.6				Y
19	7.5				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.5				Y
24	7.4				Y
25	7.3				Y
26	7.2				Y
27	7.3				Y
28	OFF				
29	OFF				
30	7.6				Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample period: APRIL 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

Alk (Alkalinity)

Print Name: Darryl Sykes
Signature: Darryl Sykes
Date & Phone#: 5/8/2023 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's