

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	7.9				Y
3	7.8				Y
4	7.8				Y
5	7.9				Y
6	8.1				Y
7	7.8				Y
8	7.8				Y
9	7.8				Y
10	7.7				Y
11	7.7				Y
12	7.7				Y
13	7.7				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.5				Y
26	7.5				Y
27	7.5				Y
28	7.5				Y
29	7.6				Y
30	7.5				Y
31	7.5				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100792**

**SCAPPOOSE, CITY OF**

Sample period: Aug 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
Alk            (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 9/11/2023 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0