

Day	pH	Alk	Phos	Other	Y/N
1	OFF				OFF
2	7.6				Y
3	7.4				Y
4	7.5				Y
5	7.5				Y
6	OFF				OFF
7	7.5	108			Y
8	7.5				Y
9	OFF				OFF
10	7.4				Y
11	OFF				OFF
12	OFF				OFF
13	7.6	106			Y
14	7.6				Y
15	OFF				OFF
16	7.9				Y
17	OFF				OFF
18	7.7				Y
19	OFF				OFF
20	7.6	109			Y
21	7.6				Y
22	7.4				Y
23	OFF				OFF
24	7.5				Y
25	OFF				OFF
26	7.5	111			Y
27	7.6				Y
28	OFF				
29	7.5				Y
30	7.5				Y
31	7.5				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-B**

**PWS ID 4100792**

**SCAPPOOSE, CITY OF**

Sample period: January 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes  
Signature: Darryl Sykes  
Date & Phone#: 2/6/21 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0