

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.5	110			Y
2	OFF				OFF
3	7.6				Y
4	7.5				Y
5	OFF				OFF
6	7.4				Y
7	7.4				Y
8	7.3				Y
9	7.3	105			Y
10	7.3				Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.4				Y
16	7.3				Y
17	7.3				Y
18	7.4	109			Y
19	7.3				Y
20	7.5				Y
21	7.5				Y
22	OFF				OFF
23	OFF				OFF
24	7.4	111			Y
25	7.5				Y
26	7.5				Y
27	OFF				OFF
28	7.6				Y
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**  
**EP-B**

**PWS ID 4100792**  
**SCAPPOOSE, CITY OF**

Sample period: FEBRUARY 2021  
 Month/Year

Number of excursions during this month: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes  
 Signature: Darryl Sykes  
 Date & Phone#: 3/8/2021 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0