

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.5	109			Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.6				Y
8	7.6				Y
9	7.5				Y
10	7.2				Y
11	7.4				Y
12	7.4				Y
13	7.2				Y
14	7.2				Y
15	7.3				Y
16	7.2				Y
17	7.4	119			Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.3				Y
23	7.5				Y
24	7.5				Y
25					
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	7.5				Y
30	7.4				Y
31	7.3	97			Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**

**EP-B**

**PWS ID 4100792**

**SCAPPOOSE, CITY OF**

Sample period: MAY 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.2
-----

  
Alk 

90.0
------

 (Alkalinity)

Print Name: Darryl Sykes  
Signature: Darryl Sykes  
Date & Phone#: 6/4/2021 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 

0
---