

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.5	107			Y
4	7.6				Y
5	7.6				Y
6	7.5				Y
7	7.4				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.4				Y
13	7.5				Y
14	7.4				Y
15	7.3				Y
16	7.9				Y
17	7.6				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.3	102			Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.7				Y
26	7.4				Y
27	7.6				Y
28	7.6				Y
29	7.5	110			Y
30	7.5				Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT

EP-B

PWS ID 4100792

SCAPPOOSE, CITY OF



Sample period: JUNE 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.2

Alk

90.0

 (Alkalinity)

Print Name: Darryl Sykes
Signature: Darryl Sykes
Date & Phone#: 7/7/2021 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
