

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.4	112			Y
3	7.4				Y
4	7.3				Y
5	7.4	113			Y
6	7.4				Y
7	7.2				Y
8	7.2	110			Y
9	7.6				Y
10	7.5				Y
11	OFF				OFF
12	7.4				Y
13	OFF				OFF
14	7.4				Y
15	OFF				OFF
16	7.4				Y
17	7.4				Y
18	OFF				OFF
19	7.4				Y
20	OFF				OFF
21	OFF				OFF
22	7.3	109			Y
23	7.4				Y
24	7.5				Y
25	OFF				OFF
26	7.4				Y
27	OFF				OFF
28	7.5				Y
29	7.4	105			Y
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT  
EP-B**

**PWS ID 4100792  
SCAPPOOSE, CITY OF**

Sample period: NOVEMBER 2021  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes  
Signature: Darryl Sykes  
Date & Phone#: 12/2/2021 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0