

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.3				Y
7	7.4				Y
8	7.4				Y
9					
10	7.4				Y
11	7.3				Y
12	7.3				Y
13	7.4	108			Y
14	7.4				Y
15	7.3				Y
16	7.3	121			Y
17	7.4				Y
18	7.3				Y
19	7.5				Y
20	7.3	122			Y
21	7.5				Y
22	7.3				Y
23	7.4				Y
24	7.3				Y
25	7.5				Y
26	7.3				Y
27	7.4	125			Y
28	7.4	125			Y
29	7.7				Y
30	7.4				Y
31	8.0				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT
EP-B
PWS ID 4100792
SCAPPOOSE, CITY OF

Sample period: MARCH 2023
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH	7.2
Alk	90.0 (Alkalinity)

Print Name: Darryl Sykes
 Signature: Darryl Sykes
 Date & Phone#: 4/10/23 503-369-0297

Send to DWP within 10 days after end of sampling period