

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.5				Y
3	7.6				Y
4	7.3	116			Y
5	8.1				Y
6	7.8				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.6				Y
11	7.3	120			Y
12	7.3				Y
13	7.4				Y
14	7.5				Y
15	7.4	124			Y
16	7.3				Y
17	7.6				Y
18	7.6				Y
19	OFF	_____			
20	7.5				Y
21	OFF	_____			
22	7.4				Y
23	OFF	_____			
24	7.4	119			Y
25	OFF	_____			
26	7.5				Y
27	7.4				Y
28	7.4				Y
29	7.2				Y
30	7.4				Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT
EP-B

PWS ID 4100792
SCAPPOOSE, CITY OF

Sample period: APR 12 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.2

Alk

90.0

 (Alkalinity)

Print Name: Darryl Syles

Signature: Darryl Syles

Date & Phone#: 5/8/2023 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0