

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.7	140			Y
3	7.6				Y
4	7.7				Y
5	OFF				
6	7.6				Y
7	7.7				Y
8	7.6				Y
9	7.6				Y
10	7.4				Y
11	7.7				Y
12	7.5	138			Y
13	7.5				Y
14	7.4				Y
15	7.6				Y
16	7.7				Y
17	7.8				Y
18	7.6	126			Y
19	7.8				Y
20	7.5				Y
21	7.6				Y
22	7.4				Y
23	7.3				Y
24	7.2				Y
25	7.3				Y
26	7.3				Y
27	—				—
28	7.3				Y
29	7.3				Y
30	7.3	123			Y
31	7.8				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**  
**EP-B**

**PWS ID 4100792**  
**SCAPPOOSE, CITY OF**

Sample period: MAY 2023  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.2
Alk	90.0 (Alkalinity)

Print Name: Darryl Sykes  
 Signature: Darryl Sykes  
 Date & Phone#: 6/9/2023 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0