

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	-				
3	7.4	130			Y
4	7.5				Y
5	-				
6	7.2				Y
7	7.3				Y
8	7.3				Y
9	7.4				Y
10					
11					
12					
13	7.3	128			Y
14	7.3				Y
15	7.3				Y
16	7.5				Y
17	7.3	131			Y
18	7.4				Y
19	7.4				Y
20	7.2				Y
21	7.2				Y
22	7.4				Y
23	OFF	---			
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.2	124			Y
28	7.3				Y
29	OFF	---			
30	7.3				Y
31					

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT  
EP-B**

**PWS ID 4100792  
SCAPPOOSE, CITY OF**

Sample period: NOVEMBER 2023  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes  
 Signature: [Signature]  
 Date & Phone#: 12/6/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0