

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	—				
4	7.3	129			Y
5	7.2				Y
6	7.2				Y
7	7.3				Y
8	7.3				Y
9	—				
10	7.3				Y
11	7.3				Y
12	—				
13	7.4				Y
14	7.3				
15	7.4	128			
16	—				
17	—				
18	7.3				Y
19	7.3				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.6				Y
24	7.6	134			Y
25	—				
26	7.2				Y
27	7.5				Y
28	7.4				Y
29	—				
30	7.3				Y
31	7.4				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

ENTRY POINT
EP-B
PWS ID 4100792
SCAPPOOSE, CITY OF

Sample period: DECEMBER 2023
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.2

 Alk

90.0

 (Alkalinity)

Print Name: Darryl Sikes
 Signature: Darryl Sikes
 Date & Phone#: 1/5/2024 503-369-0297
 Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0