

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2	7.3				Y
3	7.4	130			Y
4	7.3				Y
5	7.4				Y
6	7.4				Y
7	7.4				Y
8	7.5				Y
9	7.6	126			Y
10	7.4				Y
11	7.3				Y
12	7.5				Y
13	7.0				N
14	7.5				Y
15	7.5	141			Y
16	7.2				Y
17	7.3	125			Y
18	7.3				Y
19	7.2				Y
20					
21	7.4				Y
22	7.4				Y
23					
24	7.4				Y
25	7.4				Y
26					
27	7.2				Y
28	7.2				Y
29	7.3				Y
30	7.2	130			Y
31	7.3				Y

<<Have minimums been met for this day?

County: Columbia Agency: REGION 1

**ENTRY POINT**  
**EP-B**  
**PWS ID 4100792**  
**SCAPPOOSE, CITY OF**

Sample period: July 2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 90.0 (Alkalinity)

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date & Phone#: 8/8/2024 503-369-0297

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0