Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
#1	33568 E Columbia Ave	8.3	54			Y
#2	34485 E Columbia Ave	8.0	134			Y
#3	52590 Captain Roger	8.7	80			Y
	Kucera Way					
#4	Miller Road EP-B	7.8	144			Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Columbia Agency: REGION 1

DISTRIBUTION

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample Period: July 12, 2023
Month/Year

Sample Frequency: Every 36 months

Distribution Samples required: 3

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 35.0 *(Alkalinity)*

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date: 7/13/2023

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
#1	33568 E Columbia Ave	8.6	64			Y
#2	34485 E Columbia Ave	8.0	137			Y
#3	52590 Captain Roger	9.1	64			Y
	Kucera Way					Y
#4	Miller Road EP-B	7.8	130			Y

(N = No = Excursion) **Total N's** 0

<Has sample met the minimum(s)?

County: Columbia Agency: REGION 1

DISTRIBUTION

PWS ID 4100792

SCAPPOOSE, CITY OF

Sample Period: July 26, 2023
Month/Year

Sample Frequency: Every 36 months

Distribution Samples required: 3

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk 35.0 *(Alkalinity)*

Print Name: Darryl Sykes

Signature: Darryl Sykes

Date: 7/27/2023

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/