

Water Quality Parameter Monitoring
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1 | 7.5 | NA | NA | NA | Y |
| 2 | 7.4 | NA | NA | NA | Y |
| 3 | 7.5 | NA | NA | NA | Y |
| 4 | 0.0 | NA | NA | NA | Y |
| 5 | 0.0 | NA | NA | NA | Y |
| 6 | 7.5 | NA | NA | NA | Y |
| 7 | 7.6 | NA | NA | NA | Y |
| 8 | 7.5 | NA | NA | NA | Y |
| 9 | 7.5 | NA | NA | NA | Y |
| 10 | 7.6 | NA | NA | NA | Y |
| 11 | 0.0 | NA | NA | NA | Y |
| 12 | 0.0 | NA | NA | NA | Y |
| 13 | 7.5 | NA | NA | NA | Y |
| 14 | 7.5 | NA | NA | NA | Y |
| 15 | 7.5 | NA | NA | NA | Y |
| 16 | 7.6 | NA | NA | NA | Y |
| 17 | 7.5 | NA | NA | NA | Y |
| 18 | 0.0 | NA | NA | NA | Y |
| 19 | 0.0 | NA | NA | NA | Y |
| 20 | 7.5 | NA | NA | NA | Y |
| 21 | 7.5 | NA | NA | NA | Y |
| 22 | 7.4 | NA | NA | NA | Y |
| 23 | 7.6 | NA | NA | NA | Y |
| 24 | 7.4 | NA | NA | NA | Y |
| 25 | 0.0 | NA | NA | NA | Y |
| 26 | 0.0 | NA | NA | NA | Y |
| 27 | 7.6 | NA | NA | NA | Y |
| 28 | 7.5 | NA | NA | NA | Y |
| 29 | 7.5 | NA | NA | NA | Y |
| 30 | 7.5 | NA | NA | NA | Y |
| 31 | 7.5 | NA | NA | NA | Y |

<< Have
 minimums
 been met
 this day?

ENTRY POINT EP-A
PWS ID: 4100799
SEASIDE WATER DEPARTMENT

Sample Period: 2021
 Month/Yea 21-Dec

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required.)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.2

Signature: Michael Dimmick
Date: 1/3/2022

(No = N = Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period.
 DHS-Drinking Water Program, PO Box 14350, Portland, OR 971293-0350
 Phone: (503) 731-4381 Website: www.oregon.gov/DHS/ph/dwp/