Water Quality Parameter Monitoring

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	NA	NA	NA	Y
2	7.5	NA	NA	NA	Y
3	7.5	NA	NA	NA	Y
4	0.0	NA	NA	NA	Y
5	0.0	NA	NA	NA	Y
6	7.6	NA	NA	NA	Y
7	7.5	NA	NA	NA	Y
8	7.6	NA	NA	NA	Y
9	6.8	NA	NA	NA	Y
10	7.5	NA	NA	NA	Y
11	0.0	NA	NA	NA	Y
12	0.0	NA	NA	NA	Y
13	7.6	NA	NA	NA	Y
14	17.6	NA	NA	NA	Y
15	7.6	NA	NA	NA	Y
16	7.5	NA	NA	NA	Y
17	7.6	NA	NA	NA	Y
18	0.0	NA	NA	NA	Y
19	0.0	NA	NA	NA	Y
20	7.5	NA	NA	NA	Y
21	7.6	NA	NA	NA	Y
22	7.6	NA	NA	NA	Y
23	7.6	NA	NA	NA	Y
24	7.6	NA	NA	NA	Y
25	0.0	NA	NA	NA	Y
26	0.0	NA	NA	NA	Y
27	7.5	NA	NA	NA	Y
28	7.6	NA	NA	NA	Y
29	7.5	NA	NA	NA	Y
30	7.5	NA	NA	NA	Y
31	0.0	NA	NA	NA	Y

<< Have minimums been met this day?

(No = N = Excursion) **Total N's** 0

ENTRY POINT EP-A
PWS ID: 4100799
SEASIDE WATER DEPARTMENT

Sample Period: 2022
Month/Yea 22-Jun

Number of excursions during this month: _____
(Count the number of days when any WQP was less than the minimum required.

Total excursions during the previous 5 months: _____
(Over 9 excusions in 6 months is a violation. Entry Point and Distribution excursions are culmative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

For DHS use only

Minimum Water Quality Parameters as set by State:

pH **7.2**

Signature: Ronald Wanner
Date: 7/1/2022

Send to DHS within 10 days after end of sampling period.

DHS-Drinking Water Program, PO Box 14350, Portland, OR 971293-0350
Phone: (503) 731-4381 Website: www.oregon.gov/DHS/ph/dwp/