

Water Quality Parameter Monitoring  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	NA	NA	NA	Y
2	7.6	NA	NA	NA	Y
3	7.6	NA	NA	NA	Y
4	7.6	NA	NA	NA	Y
5	7.5	NA	NA	NA	Y
6	0.0	NA	NA	NA	Y
7	0.0	NA	NA	NA	Y
8	7.5	NA	NA	NA	Y
9	7.6	NA	NA	NA	Y
10	7.6	NA	NA	NA	Y
11	7.6	NA	NA	NA	Y
12	7.6	NA	NA	NA	Y
13	0.0	NA	NA	NA	Y
14	7.5	NA	NA	NA	Y
15	7.5	NA	NA	NA	Y
16	7.5	NA	NA	NA	Y
17	7.5	NA	NA	NA	Y
18	7.5	NA	NA	NA	Y
19	7.6	NA	NA	NA	Y
20	0.0	NA	NA	NA	Y
21	0.0	NA	NA	NA	Y
22	7.5	NA	NA	NA	Y
23	7.6	NA	NA	NA	Y
24	7.6	NA	NA	NA	Y
25	7.5	NA	NA	NA	Y
26	7.4	NA	NA	NA	Y
27	0.0	NA	NA	NA	Y
28	0.0	NA	NA	NA	Y
29	7.3	NA	NA	NA	Y
30	7.4	NA	NA	NA	Y
31	7.5	NA	NA	NA	Y

<< Have  
 minimums  
 been met  
 this day?

**ENTRY POINT EP-A**  
**PWS ID: 4100799**  
**SEASIDE WATER DEPARTMENT**

**Sample Period: 2022**  
 Month/Yea 22-Aug

**Number of excursions during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required.)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*For DHS use only*

**Minimum Water Quality Parameters as set by State:**

pH 7.2

**Signature:** Ronald Wanner  
**Date:** 9/1/2022

(No = N = Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period.  
 DHS-Drinking Water Program, PO Box 14350, Portland, OR 971293-0350  
 Phone: (503) 731-4381 Website: www.oregon.gov/DHS/ph/dwp/