

Water Quality Parameter Monitoring  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	0.0	NA	NA	NA	Y
2	7.5	NA	NA	NA	Y
3	7.4	NA	NA	NA	Y
4	7.6	NA	NA	NA	Y
5	7.5	NA	NA	NA	Y
6	7.3	NA	NA	NA	Y
7	7.3	NA	NA	NA	Y
8	0.0	NA	NA	NA	Y
9	7.5	NA	NA	NA	Y
10	7.5	NA	NA	NA	Y
11	7.5	NA	NA	NA	Y
12	7.4	NA	NA	NA	Y
13	7.5	NA	NA	NA	Y
14	7.5	NA	NA	NA	Y
15	0.0	NA	NA	NA	Y
16	7.3	NA	NA	NA	Y
17	7.5	NA	NA	NA	Y
18	7.4	NA	NA	NA	Y
19	7.4	NA	NA	NA	Y
20	7.4	NA	NA	NA	Y
21	7.4	NA	NA	NA	Y
22	0.0	NA	NA	NA	Y
23	7.3	NA	NA	NA	Y
24	7.5	NA	NA	NA	Y
25	7.6	NA	NA	NA	Y
26	7.5	NA	NA	NA	Y
27	7.4	NA	NA	NA	Y
28	7.4	NA	NA	NA	Y
29	0.0	NA	NA	NA	Y
30	7.3	NA	NA	NA	Y
31	7.4	NA	NA	NA	Y

<< Have  
 minimums  
 been met  
 this day?

**ENTRY POINT EP-A**  
**PWS ID: 4100799**  
**SEASIDE WATER DEPARTMENT**

**Sample Period: 2022**  
 Month/Yea 23-Jan

**Number of excursions during this month:** \_\_\_\_\_

*(Count the number of days when any WQP was less than the minimum required.)*

**Total excursions during the previous 5 months:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmative).*

*An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

For DHS use only

**Minimum Water Quality  
 Parameters as set by State:**

pH 7.2

**Signature:** Ronald Wanner  
**Date:** 2-1-23

(No = N = Excursion) Total N's 0