

Water Quality Parameter Monitoring

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	0.0	NA	NA	NA	Y
2	0.0	NA	NA	NA	Y
3	7.6	NA	NA	NA	Y
4	7.5	NA	NA	NA	Y
5	7.5	NA	NA	NA	Y
6	7.5	NA	NA	NA	Y
7	7.5	NA	NA	NA	Y
8	7.4	NA	NA	NA	Y
9	0.0	NA	NA	NA	Y
10	7.3	NA	NA	NA	Y
11	7.5	NA	NA	NA	Y
12	7.5	NA	NA	NA	Y
13	7.4	NA	NA	NA	Y
14	7.4	NA	NA	NA	Y
15	0.0	NA	NA	NA	Y
16	0.0	NA	NA	NA	Y
17	7.6	NA	NA	NA	Y
18	7.5	NA	NA	NA	Y
19	7.4	NA	NA	NA	Y
20	7.4	NA	NA	NA	Y
21	7.4	NA	NA	NA	Y
22	0.0	NA	NA	NA	Y
23	0.0	NA	NA	NA	Y
24	7.4	NA	NA	NA	Y
25	7.4	NA	NA	NA	Y
26	7.4	NA	NA	NA	Y
27	7.4	NA	NA	NA	Y
28	7.4	NA	NA	NA	Y
29	7.4	NA	NA	NA	Y
30	0.0	NA	NA	NA	Y
31	0.0	NA	NA	NA	Y

<< Have
minimums
been met
this day?

ENTRY POINT EP-A
PWS ID: 4100799
SEASIDE WATER DEPARTMENT

Sample Period: 2023
 Month/Yea 23-Apr

Number of excursions during this month: _____
(Count the number of days when any WQP was less than the minimum required).

Total excursions during the previous 5 months: _____
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

For DHS use only

**Minimum Water Quality
Parameters as set by State:**

pH 7.2

Signature: Ronald Wanner
Date: 5/1/2023

(No = N = Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period.
 DHS-Drinking Water Program, PO Box 14350, Portland, OR 971293-0350
 Phone: (503) 731-4381 Website: www.oregon.gov/DHS/ph/dwp/