

Water Quality Parameter Monitoring

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.4	NA	NA	NA	Y
2	7.5	NA	NA	NA	Y
3	7.6	NA	NA	NA	Y
4	7.5	NA	NA	NA	Y
5	0.0	NA	NA	NA	Y
6	7.4	NA	NA	NA	Y
7	7.5	NA	NA	NA	Y
8	7.3	NA	NA	NA	Y
9	7.5	NA	NA	NA	Y
10	7.5	NA	NA	NA	Y
11	7.4	NA	NA	NA	Y
12	0.0	NA	NA	NA	Y
13	7.4	NA	NA	NA	Y
14	7.4	NA	NA	NA	Y
15	7.4	NA	NA	NA	Y
16	7.5	NA	NA	NA	Y
17	7.3	NA	NA	NA	Y
18	7.5	NA	NA	NA	Y
19	0.0	NA	NA	NA	Y
20	7.3	NA	NA	NA	Y
21	7.4	NA	NA	NA	Y
22	7.5	NA	NA	NA	Y
23	7.5	NA	NA	NA	Y
24	7.5	NA	NA	NA	Y
25	7.7	NA	NA	NA	Y
26	0.0	NA	NA	NA	Y
27	7.7	NA	NA	NA	Y
28	7.6	NA	NA	NA	Y
29	7.4	NA	NA	NA	Y
30	7.3	NA	NA	NA	Y
31	7.5	NA	NA	NA	Y

<< Have
minimums
been met
this day?

ENTRY POINT EP-A
PWS ID: 4100799
SEASIDE WATER DEPARTMENT

Sample Period: 2024
 Month/Yea 24-May

Number of excursions during this month: 0
(Count the number of days when any WQP was less than the minimum required.)

Total excursions during the previous 5 months: _____
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

For DHS use only

**Minimum Water Quality
Parameters as set by State:**

pH **7.2**

Signature: Ronald Wanner
Date: 6/3/24

(No = N = Excursion) **Total N's** 0