

Water Quality Parameter Monitoring
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	NA	NA	NA	Y
2	0.0	NA	NA	NA	Y
3	0.0	NA	NA	NA	Y
4	7.4	NA	NA	NA	Y
5	7.5	NA	NA	NA	Y
6	7.5	NA	NA	NA	Y
7	7.5	NA	NA	NA	Y
8	7.5	NA	NA	NA	Y
9	7.5	NA	NA	NA	Y
10	0.0	NA	NA	NA	Y
11	7.3	NA	NA	NA	Y
12	7.5	NA	NA	NA	Y
13	7.4	NA	NA	NA	Y
14	7.4	NA	NA	NA	Y
15	7.4	NA	NA	NA	Y
16	7.4	NA	NA	NA	Y
17	0.0	NA	NA	NA	Y
18	7.4	NA	NA	NA	Y
19	7.4	NA	NA	NA	Y
20	7.4	NA	NA	NA	Y
21	7.6	NA	NA	NA	Y
22	7.5	NA	NA	NA	Y
23	0.0	NA	NA	NA	Y
24	0.0	NA	NA	NA	Y
25	7.4	NA	NA	NA	Y
26	7.5	NA	NA	NA	Y
27	7.5	NA	NA	NA	Y
28	7.5	NA	NA	NA	Y
29	7.5	NA	NA	NA	Y
30	0.0	NA	NA	NA	Y
31	0.0	NA	NA	NA	Y

<< Have
 minimums
 been met
 this day?

ENTRY POINT EP-A
PWS ID: 4100799
SEASIDE WATER DEPARTMENT

Sample Period: 2025

Month/Yea 25-Aug

Number of excursions during this month: _____
(Count the number of days when any WQP was less than the minimum required.)

Total excursions during the previous 5 months: _____
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

For DHS use only

**Minimum Water Quality
 Parameters as set by State:**

pH

7.2

Signature:

Ronald Wanner

Date:

9/2/25

(No = N = Excursion) Total N's

0

Send to DHS within 10 days after end of sampling period.

DHS-Drinking Water Program, PO Box 14350, Portland, OR 971293-0350

Phone: (503) 731-4381

Website: www.oregon.gov/DHS/ph/dwp/