



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Sili	Y/N
01	7.3				Y
02					
03	7.48				Y
04	7.26				Y
05					
06					
07					
08					
09					
10					
11					
12					
13					
14					
15					
16					
17	7.39				Y
18					
19	7.10				Y
20	7.06				Y
21	7.13				Y
22					
23	7.13				Y
24					
25					
26					
27	7.14				Y
28					
29	7.14				Y
30					
31					

<<Have minimums been met for this day

County: Lane

Agency: REGI

**ENTRY POINT  
EP-A  
PWS ID 4100833**

**DEERHORN COMMUNITY WATER ASSN**

Sample period: April 2021  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the state.

*Reference*

**Minimum Water Quality**

**Parameter(s) as set for this PWS:**

pH 7.0

**Print Name:** Darlene Valtinson  
**Signature:** Darlene Valtinson  
**Date:** 6 May 2021

*Eric Carlson 5-10-21*

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp