

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2					
3					
4					
5					
6					
7		80		Y	N
8	7.4			Y	N
9					
10					
11					
12					
13	7.26			Y	N
14		80		Y	N
15					
16					
17	7.37				
18					
19	7.45				
20		80		Y	N
21					
22	7.81			Y	N
23					
24	7.43			Y	N
25	7.46	80		Y	N
26					
27					
28					
29		80		Y	N
30	7.41				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 8 3 3

System Name: Deerhorn Community WTR ASSN
 Entry Point: 89002 Bridge St. Springfield
 Sample Period: 12/2024
Month/Year

Number of excursions* during this month: 6
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 6
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH: 7.0
 Alk: 60 (Alkalinity)
 PO4: _____ (Orthophosphate)
 Other: _____

Print Name: Diana [Signature]
 Signature: _____
 Date: 1/14/25

Send to DWP within 10 days after the sampling period

(No = N = Excursion) Total N's: 6