

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2		80			Y
3					
4					
5					
6	7.83	80			
7					
8	7.83	80			Y
9	7.26	80			Y
10					
11					
12	7.47	80			Y
13					
14	6.92				N
15	7.16	80			Y
16					
17	7.07	80			Y
18	7.08	80			Y
19	7.21				Y
20					
21					
22					
23	6.87	80			N
24					
25	7.00				Y
26					
27	7.5	80			Y
28					
29	7.3	80			Y
30					
31	7.3	80			Y
(No = N = Excursion) Total N's					2

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0 0 8 3 3

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: 01/25
Month/Year

Number of excursions* during this month: 2
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point
and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.0
Alk 68 (alkalinity)
PO4 (Orthophosphate)
Other ()

Eric Carlson 2-3-25

Print Name: Eric Carlson
Signature: [Signature]
Date: 2/2/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>