



Water Quality Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.23	80			Y
5					
6					
7	7.21	80			Y
8					
9	7.49	80			Y
10					
11					
12					
13	7.25	80			Y
14					
15	7.27	80			Y
16					
17					
18					
19	7.62	80			Y
20	7.57	80			Y
21					
22	7.50	80			Y
23	7.30	80			Y
24	7.37	80			Y
25					
26					
27	7.65	85			Y
28					
29					
30					
31					
(No = N = Excursion) Total N's					0

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41

0 0 8 3 3

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: 02/2025  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less  
than the minimum required)

Total excursions during the previous 5 months: 2  
(Over 9 excursions in 6 months is a violation. Entry Point  
and Distribution excursions are cumulative)

For OHA use only

#### Minimum Water Quality Parameters as set by

pH 7.0  
Alk 68 (Alkalinity)  
PO4 (Orthophosphate)  
Other ( )

Print Name: Dwight Anderson

Signature: [Signature]

Date: 3/4/2025

Send to DWP within 10 days after end of  
sampling period

Brian C. Smith 3/4/2025

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>