

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.62	75			Y
2					
3					
4					
5	7.39	80			Y
6	7.57	80			Y
7	7.56	80			Y
8					
9					
10					
11	7.54	80			Y
12	7.7	80			Y
13					
14	7.45	80			Y
15					
16	7.56	80			Y
17					
18	7.61	80			Y
19					
20	7.59	80			Y
21					
22	7.58	75			Y
23					
24					
25	7.58	80			Y
26					
27	7.7	80			Y
28					
29					
30					
31					

No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: MARCH 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point
and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.0</u>
Alk	<u>68</u> <small>mg/L Alkalinity</small>
PO4	<u> </u> (Orthophosphate)
Other	<u> </u> ()

Print Name: Doug Anderson

Signature: [Signature]

Date: 4/21/2025

Send to DWP within 10 days after end of
sampling period

Eric Carlson 4-2-25