

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.35	85			Y
5					
6	7.28	80			Y
7					
8	7.39	80			Y
9					
10					
11	7.21	80			Y
12					
13	7.35	80			Y
14	7.40	80			Y
15	7.41	80			Y
16					
17					
18	7.43	80			Y
19					
20	7.28	80			Y
21					
22					
23	7.34	80			Y
24					
25	7.42	80			Y
26					
27					
28	7.30	80			Y
29					
30					
31	7.45	80			Y
= N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: May 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 2
(Over 9 excursions in 6 months is a violation. Entry Point
and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
Alk 68 (Alkalinity)
PO4 (Orthophosphate)
Other ()

Eric Carlson 6-3-25

Print Name: Doug Underwood

Signature: [Signature]

Date: 6/3/2025

Send to DWP within 10 days after end of
sampling period