

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.31	80			Y
3	7.01	80			Y
4	7.35	80			Y
5					
6	7.24	80			Y
7					
8	7.23	80			Y
9					
10					
11	7.28	80			Y
12	7.34	80			Y
13	7.29	80			Y
14					
15	7.38	80			Y
16	7.30	80			Y
17					
18	7.32	80			Y
19					
20	7.31	80			Y
21					
22					
23	7.24	80	0.04		
24	7.24	80			Y
25	7.13	80			Y
26					
27	7.56	80			Y
28	7.47	80			Y
29	7.33	80			Y
30	7.45	80			Y
31					
No (N) Excursion) Totals					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: JUNE

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point
and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
Alk 68 (Alkalinity)
PO4 (Orthophosphate)
Other ()

7-3-25 Eric Carlson

Print Name: Eric Carlson

Signature: [Signature]

Date: July 2, 2015

Send to DWPP within 10 days after end of
sampling period