

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.52	80			Y
3					
4	7.52	80			Y
5					
6	7.36	80			Y
7	7.24	80			Y
8	7.29	80			Y
9	7.3	80			Y
10	7.24	80			Y
11	7.24	80			Y
12					
13	7.25	80			Y
14					
15	7.4	80			Y
16					
17	7.32	80			Y
18	7.21	80			Y
19	7.24	80			Y
20	7.26	80			Y
21					
22	7.21	80			Y
23					
24	7.31	80			Y
25	7.25	80			Y
26					
27	7.34	80			Y
28					
29	7.35	80			Y
30	7.4	80			Y
31	7.4	80			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: July 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.0</u>	
Alk	<u>6.8</u>	(<u>47</u> alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: [Signature]

Signature: [Signature]

Date: July 31, 2025

Send to DWP within 10 days after end of sampling period