

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.33	80			Y
2					
3					
4	7.23	80			Y
5					
6	7.3	80			Y
7					
8	7.15	80			Y
9	7.25	80			Y
10	7.35	80			Y
11					
12	7.45	80			Y
13					
14	7.5	80			Y
15	7.40	80			Y
16	7.45	80			Y
17	7.25	80			Y
18	7.4	80			Y
19	7.34	80			Y
20					
21					
22	7.24	80			Y
23	7.35	80			Y
24	7.31	80			Y
25					
26	7.21	80			Y
27	7.33	80			Y
28					
29	7.42	80			Y
30					
31	7.40	80			Y
No = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0 0 8 3 3

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: August 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point
and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.0

Alk

6.8

(Alkalinity)

PO4

(Orthophosphate)

Other

Eric Carlson 9-4-25

Print Name:

Signature:

Date:

Send to DWP within 10 days after end of
sampling period