

Day	pH	Alk	Phos	Other	Y/N
1	7.28	80			
2					
3					
4					
5	7.33	80			
6					
7	7.21	80			
8					
9	7.32	80			
10					
11					
12	7.35	80			
13					
14	7.31	80			
15					
16					
17	7.36	80			
18					
19	7.35	80			
20					
21	7.33	80			
22					
23	7.30	80			
24					
25					
26	7.18	80			
27					
28	7.26	80			
29					
30	7.38	80			
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: October 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	6.8	(Alkalinity)
PO4		(Orthophosphate)
Other		()

Eric Carlson 11/6/25

Print Name: Eric Carlson

Signature: [Signature]

Date: 11/6/2025

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's