

Day	pH	Alk	Phos	Other	Y/N
1	7.33	80			Y
2	7.41	80			Y
3					
4					
5					
6	7.22	80			Y
7	7.33	80			Y
8					
9	7.49	80			Y
10					
11					
12	7.65	80			Y
13					
14	7.76	80			Y
15	7.72	80			Y
16	7.95	80			Y
17					
18	7.93	80			Y
19					
20	7.84	80			Y
21	7.75	80			Y
22	7.36	80			Y
23					
24	7.35	80			Y
25					
26	7.38	80			Y
27					
28					
29	7.75	80			Y
30					
31					
0 = N = Excursion) Total N's					0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: NOVEMBER 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point
and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0
Alk	6.8 (Alkalinity)
PO4	(Orthophosphate)
Other	()

Eric Carlson 12/4/25

Print Name: Doug Underwood

Signature: [Signature]

Date: 12/4/2025

Send to DWP within 10 days after end of
sampling period