

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.56	80			Y
4					
5					
6	7.62	80			Y
7					
8	7.71	80			Y
9					
10					
11	7.76	80			Y
12					
13	7.71	80			Y
14					
15	7.71	80			Y
16					
17					
18					
19					
20	7.76	80			Y
21	7.61	80			Y
22					
23					
24	7.65	80			Y
25					
26	7.53	80			Y
27					
28	7.64	80			Y
29	7.53	80			Y
30					
31					
No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: 12/2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.0</u>	
Alk	<u>68</u>	(Alkalinity)
PO4	<u>—</u>	(Orthophosphate)
Other	<u>—</u>	()

Eric Carlson 1/5/26

Print Name: Dan Olszewski
Signature: [Signature]
Date: 1/11/2026

Send to DWP within 10 days after end of sampling period