

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.55	85			Y
3	7.51	85			Y
4					
5					
6	7.65	80			Y
7					
8	7.62	80			Y
9					
10					
11	7.57	80			Y
12					
13					
14	7.51	85			Y
15					
16	7.64	85			Y
17					
18	7.55	85			Y
19					
20					
21	7.12	80			Y
22					
23	7.21	80			Y
24	7.21	80			Y
25	7.09	80			Y
26	7.23	85			Y
27					
28	7.47	85			Y
29					
30	7.40	85			Y
31	7.53	85			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN

Entry Point: 89002 Bridge St. Springfield

Sample Period: JAN 2026

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0

Alk 6.8 (Alkalinity)

PO4 (Orthophosphate)

Other ()

Eric Carlson 2/9/26

Print Name: DON UNDERWOOD

Signature: [Signature]

Date: 2/4/2026

Send to DWP within 10 days after end of sampling period

No = N = Excursion) Total N's 0