

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.57	85			Y
3					
4	7.62	85			Y
5					
6					
7	7.6	85			Y
8					
9	7.2	85			Y
10					
11	7.2	85			Y
12	7.2	85			Y
13					
14					
15	7.2	85			Y
16					
17	7.2	85			Y
18	8.0	85			Y
19	7.6	85			Y
20	7.1	85			Y
21					
22					
23	7.1	8.5			Y
24	7.2	8.5			Y
25	7.2	8.5			Y
26					
27					
28					
29					
30					
31					

No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	8	3	3
---	---	---	---	---

System Name: Deerhorn Community WTR ASSN
Entry Point: 89002 Bridge St. Springfield
Sample Period: February 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
 Alk 6.8 (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Dave Anderson
Signature: [Signature]
Date: 3/3/2026

Anderson
06 MAR 2026

Send to DWP within 10 days after end of sampling period