



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Sili	Y/N
01	8.18				
02					
03	7.88				
04					
05					
06					
07					
08	7.35				
09					
10					
11					
12	7.22				
13					
14					
15	7.32				
16					
17					
18					
19	7.39				
20					
21	7.22				
22	7.16				
23	7.25				
24	7.31				
25	7.22				
26	7.17				
27	7.28				
28	7.02				
29	7.32				
30					
31					

<<Have minimums been met for this day

County: Lane

Agency: REGI

**ENTRY POINT  
EP-A  
PWS ID 4100833**

**DEERHORN COMMUNITY WATER ASSN**

Sample period: March 2021  
Month/Year

Number of excursions during this month: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the state.

Reference

**Minimum Water Quality**

Parameter(s) as set for this PWS:

pH 7.0

Print Name: Darlene M Valtinson  
Signature: Darlene M Valtinson  
Date: 6 April 2021  
Eric Carlson EC 4-8-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp