



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Sili	Y/N
01					
02					
03					
04					
05	7.27				Y
06					
07					
08					
09					
10					
11					
12					
13	7.39				Y
14					
15					
16					
17					
18					
19					
20					
21	7.45				Y
22					
23					
24					
25	7.49				Y
26					
27					
28					
29					
30	7.29				Y
31					

<<Have minimums been met for this day

County: Lane

Agency: REGI

**ENTRY POINT
EP-A
PWS ID 4100833**

DEERHORN COMMUNITY WATER ASSN

Sample period: Jan 2024
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the state.

Reference

Minimum Water Quality

Parameter(s) as set for this PWS:

pH 7.0

Print Name: Darlene Valtinson
Signature: Darlene Valtinson
Date: 1 Feb 2024

Eric Carlson 2/2/24
Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp