



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	PH	Alk	Phos	Sili	Y/N
01	7.09	80			Y
02					
03					
04					
05					
06					
07					
08	7.19				Y
09					
10					
11					
12					
13		80			
14	7.14				Y
15					
16	7.10				Y
17					
18					
19					
20					
21					
22					
23					
24	7.14	80			Y
25					
26					
27					
28					
29					
30	7.14				Y
31					

<<Have minimums been met for this day

County: Lane Agency: REGI

ENTRY POINT EP-A PWS ID 4100833

DEERHORN COMMUNITY WATER ASSN

Sample period: Aug 2024 Month/Year

Number of excursions during this month: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the state.

Reference

Minimum Water Quality

Parameter(s) as set for this PWS:

pH 7.0



Print Name: Darlene Valtinson

Signature: Darlene Valtinson

Date: 3 Sept 2024

Erin Carlson 9-3-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp