



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.5		.50		
2	8.5		.60		
3	8.5		.60		
4	8.6		.65		
5	8.4		.60		
6	8.5		.70		
7	8.4		.75		
8	8.5		.70		
9	8.5		.65		
10	8.4		.65		
11	8.5		.65		
12	8.5		.70		
13	8.5		.75		
14	8.5		.60		
15	8.5		.65		
16	8.5		.65		
17	8.5		.70		
18	8.4		.70		
19	8.5		.75		
20	8.5		.75		
21	8.5		.80		
22	8.5		.65		
23	8.6		.70		
24	8.7		.65		
25	8.5		.70		
26	8.5		.70		
27	8.5		.60		
28	8.5		.65		
29	8.5		.60		
30	8.6		.70		
31	8.5		.65		

(No = N = Excursion) Total N's N

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100835**

**SHANGRI LA WATER DISTRICT**

Sample period: 1-2021  
 Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3

PO4 0.5 (Orthophosphate)

Print Name: Anthony Morales

Signature: [Signature]

Date Phone#: 2/7/21 541-554-8040

Send to DWP within 10 days after end of sampling period