



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.5		.70		
2	8.5		.75		
3	8.5		.70		
4	8.5		.70		
5	8.5		.65		
6	8.5		.60		
7	8.5		.65		
8	8.5		.65		
9	8.5		.70		
10	8.5		.65		
11	8.5		.65		
12	8.5		.60		
13	8.5		.65		
14	8.5		.65		
15	8.5		.70		
16	8.5		.70		
17	8.6		.65		
18	8.5		.65		
19	8.5		.60		
20	8.5		.65		
21	8.5		.65		
22	8.5		.70		
23	8.5		.65		
24	8.5		.65		
25	8.6		.65		
26	8.5		.65		
27	8.5		.65		
28	8.5		.60		
29					
30					
31					

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100835**

**SHANGRI LA WATER DISTRICT**

Sample period: Feb / 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.3

PO4 0.5 (Orthophosphate)

Print Name: Anthony Morales

Signature: [Signature]

Date Phone#: 3/9/21 541-554-8040

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N