

Day	pH	Alk	Phos	Other	Y/N
1	8.5		.70		
2	8.6		.70		
3	8.6		.75		
4	8.6		.75		
5	8.6		.70		
6	8.5		.75		
7	8.5		.70		
8	8.6		.75		
9	8.6		.75		
10	9.0		.75		
11	8.6		.70		
12	8.5		.70		
13	8.5		.75		
14	8.6		.70		
15	8.5		.70		
16	8.5		.65		
17	8.9		.60		
18	8.6		.60		
19	8.5		.65		
20	8.5		.70		
21	8.7		.65		
22	8.7		.65		
23	8.5		.65		
24	8.5		.65		
25	8.5		.60		
26	8.6		.60		
27	8.7		.75		
28	8.9		.60		
29	8.8		.70		
30	9.0		.75		
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 4-1-21
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
 Alk _____ (Alkalinity)
 PO4 0.5 (Orthophosphate)
 Other _____ (_____)

Print Name: Anthony Morales

Signature: _____

Date: 5/3/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N