

Day	pH	Alk	Phos	Other	Y/N
1	8.5		.50		
2	8.4		.60		
3	8.4		.55		
4	8.4		.50		
5	8.4		.50		
6	8.4		.55		
7	8.5		.50		
8	8.5		.55		
9	8.5		.55		
10	8.5		.50		
11	8.5		.50		
12	8.5		.50		
13	8.7		.55		
14	8.5		.50		
15	8.4		.65		
16	8.5		.65		
17	8.6		.55		
18	8.4		.50		
19	8.4		.60		
20	8.3		.55		
21	8.4		.55		
22	8.7		.50		
23	8.8		.50		
24	8.8		.52		
25	8.7		.50		
26	8.7		.50		
27	8.6		.50		
28	8.9		.65		
29	9.0		.50		
30	9.4		.50		
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 6-1-2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
 Alk _____ (Alkalinity)
 PO4 0.5 (Orthophosphate)
 Other _____ (_____)

Print Name: Anthony Morales

Signature: _____

Date: 7-7-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N