

Day	pH	Alk	Phos	Other	Y/N
1	8.8		.55		
2	9.0		.51		
3	9.0		.50		
4	8.8		.51		
5	8.7		.50		
6	9.0		.50		
7	8.9		.59		
8	9.5		.50		
9	9.3		.55		
10	9.3		.53		
11	9.1		.55		
12	8.9		.60		
13	8.7		.58		
14	8.8		.55		
15	8.6		.52		
16	8.5		.55		
17	8.5		.60		
18	8.4		.57		
19	8.4		.50		
20	8.3		.51		
21	8.3		.60		
22	8.4		.50		
23	8.4		.50		
24	8.4		.55		
25	8.4		.55		
26	8.4		.50		
27	8.4		.53		
28	8.4		.50		
29	8.4		.51		
30	8.4		.50		
31			.50		

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00835

System Name: Shangri-La Water Dist

Entry Point: _____

Sample Period: 7-1-2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3
 Alk _____ (Alkalinity)
 PO4 0.5 (Orthophosphate)
 Other _____ (_____)

Print Name: Anthony Morales

Signature: _____

Date: 8/2/21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's N